



REPUBLIC OF THE PHILIPPINES
NATIONAL ECONOMIC AND DEVELOPMENT AUTHORITY
REQUEST FOR QUOTATION

P.R. No./Date : 18-10-461
October 23, 2018

RFQ No./Date : 18-11-347
November 9, 2018

Gentlemen/Ladies:

We would like to request you to please quote your lowest price/s for the item/s listed in the attached form. Your submission shall be prepared in accordance with the following requirements:

1. Indicate or write your quotation using this form or your company letterhead. Supplemental information, if any, using your company stationery may be attached to reflect the complete specification of bid e.g., brand name, model, pictures/brochures/literature, etc.
2. Put your quotation in a **SEALED ENVELOPE** and label the envelope with the PR and RFQ numbers or PhilGEPS Reference Number;
3. Address/send your quotation to the **NBAC Secretariat c/o the undersigned** at 2nd floor of the address below; and
4. The deadline for submission of your quotation is on 9:00 AM of NOVEMBER 16, 2018.

The mode of procurement is Shopping, with an Approved Budget for the Contract (ABC) of PhP270,000.00.

Your participation to this bidding shall be subject to the requirements as identified below:

- ✓ **Registered with PhilGEPS (Attach a copy to your quotation/offer).**
- ✓ **Quotation must be inclusive of all applicable government taxes** and subject to 5% F-VAT and 1% (PO) or 2% (JO) deductions. **Cash on Delivery (COD) will not be accepted.**
- ✓ Bids should not exceed the Approved Budget for the Contract (ABC) in the amount of PhP270,000.00
- Award shall be made by lot (please bid for all items to avoid disqualification of bid).
- Award shall be made by item.
- ✓ Bids should be valid for a **minimum of 30 calendar days** from deadline of submission of bids as indicated above.
- ✓ Procured items shall be delivered to NEDA sa Pasig.
- An Authority to Sell shall be submitted in bidding for branded ICT items (except supplies).
- For the repair of equipment/vehicle, on-site inspection of the unit shall be required before submission of bids.

ALTERNATIVE BIDS OR BID WITH MULTIPLE OPTIONS SHALL BE REJECTED (NBAC Resolution No. 7 (2012))

With the end view of obtaining the contract most advantageous to the government, NEDA reserves the right to: 1) accept or reject any or all the quotations/bids and waive any minor deviation in the bid which will not materially affect the substance of the bid; 2) award the contract on a per item/lot basis; and 3) to annul the bidding process and to reject all quotations/bids at any time prior to contract award, without thereby incurring any liability to the affected bidder or bidders.

All bidders will be informed of the results of this procurement.

The delivery schedule shall be completed within 30 calendar days from receipt of the Purchase Order.

Failure to comply with this delivery schedule shall be subject to the salient provisions of the Revised IRR of R.A. 9184, Section 68 (Liquidated Damages).

For clarifications, please contact the Procurement Management Division, c/o Ms. Gilda A. Ibno in the address/telephone numbers below.

MA. MONICA P. PAGUNSAN
Head, NBAC Secretariat

Dear Ms. Pagunsan,


Indicated below is our quotation in response to the RFQ above.....

Item No.	QTY	UNIT	ITEM/DESCRIPTION	BRAND	UNIT PRICE	TOTAL (PhP)
			Purchase of Uninterruptible Power Supply (UPS)			
1	10	unit	UPS for Servers			
2	100	unit	UPS for Workstation			
			(Please see attached Specifications)			
*Qualification and Other Requirements						
Must submit the following:						
a. PhilGEPS Registration Number; and						
b. Mayor's or Business Permit (current and valid).						
(if your Mayor's or Business Permit has been issued subject to compliance with certain conditions, please submit proof of compliance thereto. Otherwise, non-submission shall be grounds for disqualification.)						
Note: Bidders who have previously submitted the above requirements need not re-submit.						
Provided that these documents which are in the possession of NEDA are still current and valid.						
Please take note of the stated requirements above.						
Delivery Period: see stated schedule above.						
Payment Terms: Payment will be processed after the delivery of goods.						
The winning bidder shall provide Sales Invoice and Delivery Receipt.						
TOTAL:						
				Amount in Words:		
Contractor's Declaration:				CONFORME		
a. I/We have "Read and Accepted and Good for Agreement" the attached detailed specifications or Terms of Reference (TOR), whichever is applicable, with page and annexes signed by duly authorized representative of _____ (company) on the provided "Conforme Box";				Signature : _____		
b. I/We abide by this bid/quotation for the period of 30 days from the deadline of submission of bid as indicated in the Request for Quotation (RFQ) and it shall remain binding upon us; and				Name/Designation : _____		
c. I/We shall undertake, if our bid is accepted, to commence the Service Works as soon as is reasonably possible after the receipt of the Notice of Award or Notice to Commence, and deliver the whole of the Service/Works in the Job Order/Purchase Order within the time stated in the TOR/detailed specification.				Name of Company : _____		
				Cheque payment payable to: _____		
				Address : _____		
				Telephone/Fax/Email : _____		
				TIN No. : _____ ; VAT ; Non- VAT		

Purchase of Uninterruptible Power Supply (UPS)

ITEM NO	DESCRIPTION & SPECIFICATIONS
1	<p>UPS for Servers</p> <p>Specifications:</p> <p>Capacity: 2000VA/1200W</p> <p>Nominal Input Voltage: 220/230/240VAC</p> <p>Operating Frequency Range: 50/60 Hz(+/- 10%)</p> <p>Output Voltage Range (Battery Mode): Simulated Sine Wave at Nominal Voltage +/- 10%</p> <p>Frequency Range (Battery Mode): 50 or 60 Hz +/- 1 Hz</p> <p>Transfer Time: Typical 2 to 6 ms.</p> <p>Battery Type: 12V 9Ah x 2 units (Sealed Lead-Acid, Maintenance-Free)</p> <p>Typical Recharge Time: 6 to 8 Hours (to 90% of Full capacity)</p> <p>Back-up Time @ 120W Load: 39 Minutes</p> <p>System Features:</p> <p>LED Light indicator: AC Mode, Battery Mode, Fault Mode</p> <p>Protection: Discharge, Overcharge, and Overload Protection</p> <p>Alarm:</p> <p>Battery Mode: Sounding every 10 seconds</p> <p>Low Battery: Sounding every second</p> <p>Overload: Sounding every 0.5 second</p> <p>Battery Replacement: Sounding every 2 seconds</p> <p>Fault: Continuously sounding</p> <p>Safety Standards: IEC/EN62040-1, IEC/EN60950-1</p> <p>EMC Standards: IEC/EN62040-2, IEC61000-4-2, IEC61000-4-4, IEC61000-4-5 IEC61000-4-6, IEC61000-4-8</p> <p>Warranty: Minimum of One (1) Year</p>
2	<p>UPS for Workstations</p> <p>Specifications:</p> <p>Capacity: 600VA/360W</p> <p>On-Line Input Voltage: 160-290VAC, Single phase</p> <p>On-line Frequency: 50/60hz (Auto Sensing)</p> <p>On-Line Frequency Range (50/60hz): 45-55Hz ±1Hz / 55 - 65Hz ±1Hz</p> <p>Output Voltage: 220/230/240VAC. Single phase</p> <p>Output Voltage (Battery Operation): + / -10%</p> <p>Back-up Time @ 120W Load: 10 Minutes</p> <p>On-Battery Wave Form: Stepped sinewave</p> <p>Output Frequency Battery Mode: 50Hz (60Hz) ±1Hz</p> <p>Battery Type - VDC x ah x Quantity; 12V x 7 Ah x 1</p> <p>Typical Recharge Time: 4 Hours to 90%</p> <p>Outlet type and numbers: IEC C13 x 4</p> <p>Features:</p> <p>Warranty: Minimum of One (1) Year</p>


PETER JOHN B. PANELO
 CO I


EMARSON T. OCHOA
 ITO II